



NOTES:

1. For use ONLY when replacing similar curb. This curb is not intended for new construction unless preapproved by City Engineer.
2. Concrete to have compressive strength of 4,000 psi at 28 days.
3. Expansion joints to be provided at each:
 - a. Point of tangency.
 - b. Cold joint.
 - c. Side of inlet structures.
 - d. Side of driveways.
4. Expansion joint material to be pre-molded, asphalt impregnated, non-extruding, with a thickness of 1/2-inch.
5. Contraction joints shall have:
 - a. Spacing of not more than 15 feet.
 - b. Depth of Joint of at least 1 1/2-inches.
6. Base rock 2"-0 or 3/4"-0, 95% (AASHTO T-180) compaction. Base rock shall be to subgrade of street structure or 4-inches, which ever is greater, and shall extend 12-inches behind the curb.
7. Drainage weephole shall be:
 - a. 3-inch I.D. plastic pipe with coupling and beveled outlet end to match face of curb.
 - b. Centered with contraction joints.



City Of Beaverton

ENGINEERING DEPARTMENT

CITY ENGINEER
Terry Waldele, P.E.

DATE
6 - 10 - 04

TYPE 'A' REPLACEMENT CURB

DRAWN BY
IS - TSD

DRAWING NO.
203